


To set the N30P ammeter at the amp level to start the Dustop spray, use the following procedure



1.  Press & hold for 3 seconds (When SEC is displayed release the button)
2.  Press 1 time
3.  Press 1 time
4.  Press 1 time
5.  Press 3 times (ALr 1 will be displayed)
6.  Press 3 times (PrH_1 will be displayed)
7.  Press 1 time
8.  Press 3 times
9.  Press till amp digit value is reached
10.  Press 1 time
11.  Press till amp digit value is reached
12.  Press 3 times
14. Don't touch any buttons until display reads END (approximately 30 seconds)
15. You are now programmed

If you make a mistake during programming, just wait approximately 30 seconds and the unit will reset.

For 2nd alarm set point units, at step 5 press 4 times (not 3) and follow the remaining steps.

Edward J. Heck & Sons Co. 800-652-8873 email ejheck@ejheck.com